

Diagram illustrating a power distribution system (Single-line diagram) with the following components and labels:

- Supply:** L1, L2, L3, 400 / 230V: 50Hz
- Main Switches and Fuses:**
 - Q1 40A
 - Q2 25A 30mA
 - Q3 20A 30mA
 - F3 25A 30mA
 - F4 20A 30mA
 - F5 20A
 - F6 16A
 - F7 10A
- Grounding and PE Line:**
 - uzemljivač (grounding electrode)
 - PE (Protective Earth) line
 - NYRY-J 5x6 mm² (Cable cross-section)
- Load Types and Distribution Points:**
 - opća potrošnja (General consumption)
 - nužna potrošnja (Essential consumption)
 - GR (Grounding point)
 - Porta (Door)
 - Vaga (Scale)
 - Rezerva (Reserve) - multiple locations

Ovaj dokument ostaje u isključivom vlasništvu poduzeća AMPLiTUDA VALA d.o.o. Pretisak i upotreba izvan namjene nisu dopušteni.

FILE NAME: 001EJ03

MARKO ŠOŠTARIĆ mag.ing.el. E 2112 OVLASTENI INŽENJER ELEKTROTEHNIKE	Pečat i potpis projektanta:			Investitor: GRAD OSIJEK, Franje Kuhača 9, 31000 Osijek			Faza projekta: GLAVNI		Z. O. projekta: 10–005/15		Projekt broj: PG–001–15						
	Građevina: ODLAGALIŠTE NEOPASNOG OTPADA "LONČARICA VELIKA" - OSIJEK						Naziv projekta: PROJEKT ELEKTROINSTALACIJA						Knjiga: 4				
	Projektant		M. ŠOŠTARIĆ				amplituda d.o.o. Poljana Z. Mikine 26,10000 Zagreb E-mail: info@amplituda-vala.hr WEB: www.amplituda-vala.hr						Naziv dokumenta: JEDNOPOLNA SHEMA RAZDJELNIKA (RO–PV)		Broj nacрта: 001EJ03		+ –
	Glavni projektant		D. BARAĆ												List br.: 02		
	Datum 02/2015.		IME		POTPIS								Format: A3	Mjerilo: –	Listova: 05		